

Lincoln Elementary School**Lead Level ug/L**

	Lead Level ug/L
Basement Kitchen food prep sink	1.1
1st Floor Room 9 sink with water fountain	1.8
1st Floor Nurses Office sink	2.1
Basement Room B3 sink	2.2
3rd Floor Water Fountain outside Room 31	2.9
Basement Room B2 sink	5.7
3rd Floor Room 38 sink	6.8
2nd Floor Room 20A sink	28
3rd Floor Water Fountain outside Boys Bathroom	< 1.0
3rd Floor Room 31 sink	< 1.0
2nd Floor Water Fountain outside Room 24	< 1.0
2nd Floor Water Fountain outside Boys Bathroom	< 1.0
1st Floor Water Fountain outside Main Office	< 1.0
1st Floor Water Fountain across from Room 4	< 1.0
1st Floor Room 1 sink with water fountain	< 1.0
Basement Water Fountain outside Cafeteria	< 1.0