

| SCLA | Lead Level ug/L |
|--|-----------------|
| 2nd Floor Annex Room A205 Coffee Maker | 0.83 |
| 2nd Floor Annex Room A206 prep sink | 1.1 |
| 1st Floor Hallway water fountain outside Room B102 | 1.4 |
| 3rd Floor Hallway water fountain outside Room B303 | 1.5 |
| 2nd Floor Annex Room A205 Ice Maker | 1.7 |
| 1st Floor Annex Main Office sink | 3 |
| 2nd Floor Hallway water fountain outside Room B202 | 3.4 |
| 3rd Floor Room B301 sink #2 | 3.6 |
| 3rd Floor Room B301 sink #3 | 3.7 |
| 1st Floor Annex Cafeteria water fountain near Boys Bathroom | 3.7 |
| 2nd Floor Hallway Annex water fountain outside Library | 3.8 |
| 1st Floor Annex Nurses Office sink #2 | 3.9 |
| 2nd Floor Annex Room A203 sink #2 | 4.3 |
| 2nd Floor Annex Room A203 sink #1 | 4.7 |
| 1st Floor Hallway Annex water fountain outside Girls Locker Room | 4.8 |
| 1st Floor Annex Nurses Office sink #3 | 5.1 |
| 1st Floor Annex Choral Room 1 sink | 5.2 |
| 1st Floor Annex Kitchen sink | 6.9 |
| 1st Floor Annex Nurses Office sink #1 | 7.2 |
| 1st Floor Annex Nurses Office sink #4 | 7.2 |
| 2nd Floor Hallway water fountain outside Room B210 | 9.3 |
| 2nd Floor Annex Room A205 sink | 10.7 |
| 3rd Floor Room B303 sink #4 | 12.5 |
| 3rd Floor Room B302 sink #2 | 12.5 |
| 3rd Floor Room B306 sink #3 | 14.3 |
| 3rd Floor Room B301 sink #1 | 16.1 |
| Basement Room B10 sink | 21 |
| 3rd Floor Room B306 sink #4 | 22.1 |
| 3rd Floor Room B301 sink #4 | 35.6 |
| 1st Floor Annex Choral Room 2 sink | 65.2 |
| 2nd Floor Annex Room A206 sink | 67.1 |
| 3rd Floor Room B303 sink #3 | 67.6 |
| 3rd Floor Room B301 closet sink #2 | 94 |
| 3rd Floor Room B306 sink #5 | 95.2 |

| | |
|--|-----------|
| 2nd Floor Annex Library Office sink | 151 |
| 3rd Floor Room B306 sink #1 | 279 |
| 2nd Floor Annex Room A204 sink #1 | 327 |
| 3rd Floor Room B303 sink #1 | 483 |
| 3rd Floor Room B301 closet sink #1 | 630 |
| 2nd Floor Annex Room A204 sink #2 | 800 |
| 3rd Floor Room B303 sink #2 | No Sample |
| 3rd Floor Room B302 sink #1 | No Sample |
| 3rd Floor Room B302 sink #3 | No Sample |
| 3rd Floor Room B302 sink #4 | No Sample |
| 3rd Floor Room B306 sink #2 | No Sample |
| 1st Floor Hallway water fountain outside Room B110 | No Sample |
| 2nd Floor Annex Room A201 sink | No Sample |
| 2nd Floor Annex Room A202 sink #1 | No Sample |
| 2nd Floor Annex Room A202 sink #2 | No Sample |