

Schenectady High School**Lead Level ug/L**

Hallway water fountain E-Wing next to Girls Bathroom	0.13
Hallway water fountain E-Wing next to Boys Bathroom	0.22
Training Room Ice Machine	0.27
Pool Complex Boys Locker Room sink #1	0.31
2nd Floor Hallway water fountain FA-Wing across from Room FA20 #1	0.36
2nd Floor Hallway water fountain FA-Wing across from Room FA20 #2	0.4
2nd Floor FA-Wing Room 27 sink #2	0.52
2nd Floor FA-Wing Room 27 sink #1	0.53
2nd Floor FA-Wing Room 26 sink #1	0.76
2nd Floor FA-Wing Room 26 sink #2	0.86
2nd Floor FA-Wing Room 25 sink #2	0.92
2nd Floor FA-Wing Room 25 sink #1	0.94
Room D16 sink #5	1
Hallway water fountain next to Guidance Suite	1.1
Main Gym water fountain #2	1.2
Kitchen prep sink #3	1.2
Room A10 sink	1.2
Boys Locker Room Office sink #1	1.4
Room B12 sink	1.4
Hallway water fountain B-Wing across from Room B7	1.4
Hallway water fountain AB-Wing next to Room AB9	1.6
Room D5 sink #6	1.7
Room D16 sink #4	1.7
Cafeteria Serving Line sink #1	1.9
Kitchen prep sink #1	1.9
Hallway water fountain E-Wing next to Room E7	1.9
Pool Complex Girls Locker Room sink #1	1.9
Hallway water fountain next to Room E6	2.1
Cafeteria water fountain	2.2
Room D16 sink #2	2.2
Pool Complex Girls Locker Room sink #2	2.2
Kitchen sink #1	2.3
Room E6 sink #6	2.6
Room E5 sink #6	2.7

Room D16 sink #3	2.7
Pool Complex Boys Locker Room sink #2	2.9
Kitchen sink #3	3
Hallway water fountain outside Main Gym #1	3.2
Room A9 sink	3.2
Room D44 sink #3	3.3
Room E4 sink #2	3.4
Room E7 sink #7	3.4
Hallway water fountain outside Main Gym #2	3.6
Hallway water fountain A-Wing across from Room A14	3.8
Main Hallway water fountain across from Auditorium #1	3.8
Nurses Office sink #3	4
Room E9 sink #2	4.1
Room E6 sink #2	4.3
Room FA10 sink	4.5
Room B1 sink	4.6
Room E6 sink #4	4.8
Hallway water fountain B-Wing across from Room B20	5.2
Nurses Office sink #2	5.2
Hallway water fountain A-Wing across from Room A1	5.6
Nurses Office sink #5	5.6
Room D47 sink #3	5.7
Room E9 sink #3	5.9
Room A8 sink	5.9
Room E9 sink #5	6.3
Room E7 sink #4	6.3
Room E6 sink #3	6.4
Room B23 sink	6.4
Room D39 sink	6.6
Room E5 sink #1	6.6
Room E9 sink #4	6.6
Room D50 sink #1	6.7
Room D4 sink #7	6.8
Kitchen sink #2	6.8
Room D51 sink #3	6.9

Room E7 sink #5	7.1
Room D50 sink #7	7.2
Room D16 sink #1	7.4
Room D17 sink #3	7.5
Room D50 sink #3	7.9
Room E5 sink #2	8
Room E5 sink #4	8.2
Room D47 sink #2	8.3
Room A11 sink	8.4
Room E4 sink #3	8.6
Hallway water fountain across from Room D6B	8.7
Training Room sink	8.9
Room D52 sink #7	8.9
Room D47 sink #4	8.9
Room E5 sink #5	8.9
Room E6 sink #1	8.9
Room E4 sink #4	8.9
Room D47 sink #7	9.2
Room E7 sink #3	9.3
Room D51 sink #6	9.5
Room E5 sink #3	9.7
Auditorium Stage sink	9.9
Room E7 sink #6	10
Room A1 sink	10.1
Room E6 sink #5	10.5
Main Office water fountain next to Room D137	10.5
Hallway water fountain Main Hallway outside Commons	11.2
Room D2 sink #3	11.2
Room D8 sink #1	11.3
Room E9 sink #6	11.4
Room D2 sink #6	11.5
Room E9 sink #1	11.5
Room D50 sink #4	12.1
Room D47 sink #1	12.1
Main Gym water fountain #3	12.2

Kitchen prep sink #2	12.6
Room E8 sink #7	13
Hallway water fountain B-Wing across from Room B17	13.2
Room E4 sink #1	13.6
Room E4 sink #5	13.6
Room E4 sink #6	13.6
Room D49B sink	13.6
Hallway water fountain Middle D-Wing next to Boys Bathroom	13.7
Boys Locker Room water fountain	13.9
Main Hallway water fountain across from Auditorium #2	15.7
Room E7 sink #2	16.5
Nurses Office sink #1	16.8
Room D2 sink #7	17
Room E7 sink #1	17.2
Room D50 sink #5	17.3
Room D51 sink #2	18.1
Cafeteria Serving Line sink #2	18.2
Room D47 sink #6	18.6
Room D44 sink #6	18.7
Room D27 sink #1	18.7
Room D27 sink #2	19.4
Room D50 sink #6	19.6
Room D2 sink #1	19.9
Room D1 sink #1	20.2
Nurses Office sink #4	20.5
Boys Locker Room Office sink #2	20.8
Room D2 sink #5	22.2
Room D47 sink #5	24.3
Room D44 sink #1	24.6
Room D9 sink #6	24.6
Room D23 sink	24.8
Room D2 sink #2	26.3
Room D25 sink	26.5
Room D50 sink #2	27.2
2nd Floor FA-Wing Room 27 sink #3	27.2

Room D2 sink #4	27.6
Room D51 sink #5	28.6
Room E8 sink #5	28.8
Room D26 sink #1	29
Room E8 sink #1	29.1
Room D1 sink #2	29.4
Weight Room water fountain	30.1
Room E8 sink #3	31.6
Room D24 sink	32.4
Room E8 sink #6	32.8
Room D51 sink #4	33.6
Room D1 sink #5	33.9
Room D1 sink #7	33.9
Room E8 sink #2	33.9
Room D1 sink #3	34.6
Room E8 sink #4	35.9
Room D51 sink #1	36.8
Room D44 sink #7	39.5
Room D51 sink #7	40
Room D1 sink #4	40
2nd Floor FA-Wing Room 21 sink #1	40.1
Room D46 sink #7	42.2
Room D9 sink #7	44
Room D1 sink #6	44.8
Room D26 sink #2	45.6
Room D22 sink #1	47.9
Main Gym water fountain #1	48.8
2nd Floor FA-Wing Room 20 sink	51.9
2nd Floor FA-Wing Room 23 sink #1	52.6
2nd Floor FA-Wing Room 23 sink #2	58.7
Room D9 sink #5	61.6
Room D44 sink #5	69.8
Room D8 sink #6	69.8
Room D46 sink #5	70.6
Room D46 sink #6	73.5

Room D44 sink #2	75.6
Room D22 sink #2	77.1
Room D46 sink #1	77.2
Room D9 sink #4	84
Room D5 sink #4	93.9
Room D8 sink #4	95.1
2nd Floor FA-Wing Room 21 sink #2	107
Room D8 sink #5	114
Room D46 sink #4	118
Room D52 sink #3	124
Room D52 sink #5	125
Room D8 sink #3	125
Room D8 sink #2	127
Room D4 sink #6	136
Room D9 sink #3	139
Room D5 sink #7	141
Room D52 sink #1	145
Room D46 sink #2	200
Room D52 sink #2	222
Room D9 sink #2	225
Room D5 sink #5	242
Room D46 sink #3	246
Room D4 sink #2	269
Room D52 sink #4	320
Room D52 sink #6	366
Room D28 sink in closet	615
Room D4 sink #4	6260
Hallway water fountain FA-Wing across from Room FA1 #1	< 1.0
Hallway water fountain FA-Wing across from Room FA1 #2	< 1.0
Hallway water fountain FA-Wing across from Room FA1 #1	< 1.0
2nd Floor Hallway water fountain FA-Wing next to Room FA25 #1	< 1.0
2nd Floor Hallway water fountain FA-Wing next to Room FA25 #1	< 1.0
Room D14 sink	12.8 OR 49.4
Room D15 sink	16.9 OR 245
Room D5 sink #2	MISSING SAMPLE

Room D9 sink #1	MISSING SAMPLE
Room D44 sink #4	NO SAMPLE
Room D21 sink	NO SAMPLE
Room D5 sink #1	NO SAMPLE
Room D5 sink #3	NO SAMPLE
Room D4 sink #1	NO SAMPLE
Room D4 sink #3	NO SAMPLE
Room D4 sink #5	NO SAMPLE
2nd Floor FA-Wing Room 22 sink #1	NO SAMPLE
2nd Floor FA-Wing Room 22 sink #2	NO SAMPLE
Room D11 sink	NO SAMPLE
Room D10 sink	NO SAMPLE
Room D17 sink #1	NO SAMPLE
Room D17 sink #2	NO SAMPLE