

Washington Irving**Lead Level ug/L**

Washington Irving	Lead Level ug/L
1st Floor Room 102 sink in closet	0.49
2nd Floor Hallway water fountain outside Room 202	1.3
1st Floor Hallway water fountain across from Room 105	1.6
3rd Floor Room 309 sink #2	6.3
2nd Floor Womens Bathroom sink	7
3rd Floor Hallway water fountain next to Boys Bathroom	8.3
2nd Floor Hallway water fountain outside Room 210	8.5
3rd Floor Hallway water fountain next to Girls Bathroom	12.6
Basment Custodian Room sink	14.2
1st Floor Room 104 sink in closet	16.8
3rd Floor Room 309 sink #1	20.4
Basement Book Storage Room sink	26.9
Basement Room B4 sink #1	30.5
2nd Floor Kitchen prep sink	42.7
2nd Floor Room 202 sink in closet	67.1
2nd Floor Room 208 sink in closet	77.1
2nd Floor Room 203 sink in closet	89.5
1st Floor Room 105 sink in closet	128
3rd Floor Room 307 sink in closet	323
1st Floor Hallway water fountain next to Main Office	386
2nd Floor Cafeteria Coffee Machine	NO SAMPLE
Basement Room B4 sink #2	NO SAMPLE